

KERSHAW COUNTY Sewer Service Line Requirements

- Pipe used for sanitary sewer shall be schedule 40-DWV polyvinyl chloride (PVC)
- Contractor shall install one backflow device next to house
- Contractor shall install one clean out in front of backflow device, this will be considered the customers cleanout
- Contractor shall install one elder valve as close to property line as possible or within two feet of main sewer line
- Any bends greater than 45 degrees will have an additional clean out prior to bend
- All connections shall be primed and clued
- All clean out accesses will be required to be at a minimum of four inches above grade
- All clean out accesses will have a male threaded cap
- At a minimum sewer line must be left exposed at the house and at the tap for inspection purposes, if not left exposed KERSHAW COUNTY may require line to be TV inspected and or dug up for inspection at the contractors expense.

UTILITY DEPARTMENT